



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board
Division of Drinking Water

May 25, 2018

Butte City Community Services District
P.O. Box 141
Butte City, CA 95920

Attention: Joe Regoli, Board Chair

**SUBJECT: NOTICE OF VIOLATION NO 21-18N-006, PUBLIC WATER SYSTEM NO. 1100711 –
FAILURE TO COLLECT A ROUTINE BACTERIOLOGICAL SAMPLE IN APRIL 2018.**

The California Code of Regulations (CCR), Title 22, Article 3, Section 64423, requires that each public water system collect routine bacteriological samples from the distribution system, based on the number of service connections or the population served.

Our records show that Butte City Community Services District (hereinafter, System) operates a community water system, which is required to collect and report a minimum of one routine bacteriological water quality sample per month.

In reviewing our records, we note that **the System did not collect and/or report a routine bacteriological sample to the Division during the month of April 2018.**

This violation could require public notification within 30 days and a citation with possible fines.

The System is required to note this failure in the 2018 Consumer Confidence Report.

By sending this letter we are clearly informing the System about the routine sampling responsibilities under the CCR.

If you have any questions regarding this matter, please call Paul Rowe at (530) 224-4866 or me at (530) 224-4861.

A handwritten signature in black ink, appearing to read "R. Crenshaw".

Reese B. Crenshaw, P.E.
Valley District Engineer
DRINKING WATER FIELD
OPERATIONS BRANCH